

VENDOR NAME

ADDRESS

TELEPHONE NUMBER

FAX NUMBER

NAME AND TITLE OF PREPARER

TYPE OF BUSINESS

(partnership, corporation, etc.)

OF YEARS IN CURRENT BUSINESS

OF YEARS AT CURRENT LOCATION

PRIOR ADDRESS (if at current
address less than 5 years)

CERTIFIED IN REPAIR OF PUMPS
OR PLUMBER LICENSE NO.

NAME ON LICENSE

EXPIRATION DATE

PROOF OF TRAINING IN
CONFINED ENTRY

PROOF OF 40 HOURS OF HAZ-MAT
TRAINING

Are the persons listed above, a principal of the company or a full time employee?

What is the zoning classification of the property upon which your facility is located?

SPECIFICATIONS

COMPREHENSIVE MAINTENANCE OF LANDFILL LEACHATE PUMPS

NOTE: BIDDERS ARE ENCOURAGED TO VISIT THE SITE. APPOINTMENTS MAY BE MADE BY CONTACTING TOM VETRI AT THE LANDFILL AT 631-249-9347.

SCOPE

It is the intent of this bid to fully cover all labor and/or parts and associated components for the existing leachate pump system installed at the Town's landfill. A list of the pumps and associated components is given in this bid under "Description and Location of Equipment".

Repairs as well as those performed as part of on-call/emergency service will be billed under the bid labor rates and a percent over cost for all materials and/or equipment. The Town reserves the right to bid out separately any major repair work.

GENERAL

1. Maintenance and Overhaul when requested

- All pumps will be pulled, cleaned and disassembled;
- Inspect all pumps' internal parts, i.e., impeller, shaft, seals and bearings;
- Inspect all pump motor wires for shorts, broken insulation, poor or corroded splice connections;
- Assemble pump and install in service, check proper settings for level controls;
- Check pump output

2. On-Call/Emergency Service

The contractor is to respond to repair work, emergency service calls within 24 hours. The contractor will inspect the equipment and inform the Town as to the nature of the required repairs and the estimated cost for repairs. The Town reserves the right to inspect and verify all major repairs, and to bid separately any major equipment replacements or additions if deemed to be in the best interest of the Town. The authorized repairs will be billed under the bid labor rates and a percent over cost fee for materials and/or equipment.

3. Continuity of Service

The Contractor is to respond to any service call or repair work upon the telephone request of the Commissioner of Environmental Control or their designated agents.

All scheduled work will be performed only during the hours of 7:00 A.M. to 3:30 P.M., Monday through Friday (except Holidays) unless requested by the Commissioner of General Services or the Commissioner of Environmental Control.

Emergency Service Calls will be given priority consideration and will be responded to within 24 hours. Based upon the nature of the emergency, response time may be extended beyond 24 hours at the Town's discretion.

BIDDER QUALIFICATIONS

Proposers must have 10 years experience in the maintenance, repair and replacement in industrial water pumps, electric motors and their controls at municipalities and large commercial facilities.

The Town will require the successful bidder to be certified in the repair of pumps or be a licensed plumber. In addition, proof of training in confined entry and 40 hours of haz-mat training will be required of the successful bidder. Sub contracting shall not be permitted.

Contractor to have adequate inventory of parts, materials and components required to service existing Town of Babylon equipment as listed in the section "Description and Location of Equipment", and will be readily available for use at all times. This inventory is subject to confirmation and inspection by the Town.

Contractor shall be confined space entry certified and hazmat certified.

Contractor shall have fully stocked service vans with normal replacement parts for making minor repairs and/or replacements. Proposers shop locations must be properly zoned and be in full compliance with local zoning requirements.

Contractor is to include a sample of an inspection and service record that would be kept to verify maintenance work performed under this contract. **Contractor's employees are to sign in and/or out at facility where work is performed.** No payment for travel time will be allowed.

INSPECTION

All prospective bidders are encouraged to visit each site to familiarize themselves with the equipment and systems involved. It is the Town's intention to have all the landfill's leachate pumps and associated equipment covered under this contract. It is the proposers responsibility to notify the Town if the equipment listed is inaccurate or if any equipment has been inadvertently omitted. **The Landfill Field Office is located at 57 Field Street, West Babylon, New York, Telephone No. (631) 249-9347. Contact Deputy Commissioner of Environmental Control, Tom Vetri for an appointment.**

CHANGE TO SYSTEMS

If the owner causes the systems included in this agreement to be changed in any material respect, this agreement shall be modified to incorporate such changes with reasonable price increases.

LABOR RATES

The Town will consider, after the first year of the contract, any contractual labor rate increase incurred by the contractor during the term of the contract. The Town reserves the right to approve or disapprove of any wage rate increase requests.

DESCRIPTION AND LOCATION OF EQUIPMENT

The following comprises the equipment, including its associated components that will be covered by all the terms of this contract:

I. Southern Ashfill

3 Peabody Barnes Pumps Model 4XSE10034A

2 Peabody Barnes Pumps Model R45E7.52

Parts and Associated Equipment Covered:

all pump controls, switches, flow meters, alarm panels, valves, fittings and gaskets.

II. Northern "U" Ashfill

2 EPG Model WSDPT 8-2

Parts and Associated Equipment Covered:

all pump controls, switches, flow meters, alarm panels, valves, fittings and gaskets.

III. Tie In Manhole

Butterfly Valves and Check Valves

TECHNICAL INFORMATION Provided by Town upon request

1. Primary Lechate Pump Station - Southern Ashfill - by Quimby Equipment
2. Operation & Maintenance manual for Town of Babylon by EPG Companies
3. Control Schematics for Southern Ashfill and Northern Ashfill

NOTE: THE SUCCESSFUL VENDOR WILL BE REQUIRED TO SUBMIT CERTIFICATES OF INSURANCE AS PER THE ATTACHED REQUIREMENTS.