

**ADDENDUM NO. 1  
BID NO. 14G64**

**FUEL OIL #2**

**August 21, 2014**

\*\*To All Bidders,

This addendum is hereby made part of the contract documents for BID No. 14G64, Fuel Oil #2; Please note the revisions/clarifications described herein and submit your bids accordingly.

**THIS ADDENDUM MUST BE INCLUDED WITH YOUR BID.**

**Clarification to specs:**

The specs stated that “Most deliveries shall be made on an automatic basis. Some deliveries shall be on call”.

Those two statements are being amended and should read as follows:

“All deliveries shall be made on an automatic basis. Any calls for delivery are considered to be an emergency”.

**ADDENDUM NO. 1  
BID NO. 14G64**

**FUEL OIL #2**

**August 21, 2014**

**Additional Information on tank locations:**

<b><u>Locations</u></b>	<b><u>Capacity</u></b>	<b><u>underground vs above ground</u></b>
Town Hall	10,000	under
Town Hall Annex	10,000	under
Highway Dept	10,000	under
Central Garage	500	above
Street Lighting	1,500	under
Sign Shop	275	above
Buildings & Grounds Stock Room	275	above
ACE Center	1,000	under
Residential Recycling	275	above
	2,000	under
Tanner Park	2,000	under
Veterans Bldg	275	above
Gilgo Beach Lifeguard Bldg	275	above
Cedar Beach Marina Maint.	550	above
Special PPC Bldg (Fire Marshall/Haz Mat)	275	above